

**From:** [rcwebcontact](#)  
**To:** [Rules Coordinator](#)  
**Subject:** The Form "Rules Comment Form" was submitted  
**Date:** Thursday, June 2, 2022 3:37:10 PM



# General Comment

Here is a new comment from the Web.

## Comment

### Choose Form

Chapter 9 (SB 1582 and SB 1668, 2021)

### Name

Lon Holloway

### Address

20096 CR 173

### City

BULLARD

### State

TX

### Zip

75757

### Business Phone, Fax

12147739284

### **Email Confidentiality Preference**

No, I request my e-mail address to remain confidential

### **Email Address**

[REDACTED]

### **Comments concerning proposed rulemakings**

June 02, 2022 9.2 Definitions: Good with this 9.7 An emergency telephone number is not needed if a company is denied a license. 9.29 Not a big issue since none have applied to my knowledge, but there needs to be a process. 9.20 Only applies to DOT cylinders, none of the other activities that apply at a normal dock are referred to. Does little to train an employee to manage all applications of a normal dock application. Only helps for cylinder exchange licensee. 9.55 Very poorly written and still very restrictive. 9.52 Managers typically have the time to look up rules and regulations more than any other certified job title. Manager certification should be open book and not require the 80-hour course. If you test and pass your good. If you fail you pay the fee again. 9.126 Electronic actuators, "Enhance public safety" 9.134 Does this remove the licensee from being the RRC Police?? File it and say unknown but do the due diligence. 9.143 Should be what the TPGA ask for. 9.140 Forklift cage protection as a standalone protection never going to happen without a standard for the cage. Uniform protection for bulk tanks is so butchered, throw it out and start over. Uniform fire code language without a reference, is a good starting point. The RRC still does not identify the diameter of the hole required to concrete a vertical crash post into the ground. 9.403 We need to be moving toward the 2020 version Will the Fire Safety Analysis be in conjunction with the size tank required for drawings as we previously discussed with April? When the new rules are adopted and printed, please indicate any new rules including those that apply to the January 2020 edition by highlighting or shading similar to NFPA Regards, Lon Holloway

